

NEC-ARTICLE 210.63 HEATING, AIR CONDITIONING, AND REFRIGERATION EQUIPMENT OUTLET FOR MANUFACTURED HOMES

Update!!! The Electrical Board, at the February 6, 2003, Board Meeting, reviewed and upheld the Bureau's position regarding the National Electrical Code, NEC 210.63, Heating, Air Conditioning and Refrigeration Equipment Outlet. It is the Board's opinion that the requirements of NEC Article 210.63, "A 125-volt, single-phase, 15- or 20-ampere-rated receptacle outlet shall be installed at an accessible location for the servicing of the heating, air-conditioning, and refrigeration equipment. The receptacle shall be located on the same level and within 7.5 m (25 ft.) of the heating, air-conditioning, and refrigeration equipment. The receptacle outlet shall not be connected to the load side of the equipment disconnecting means". This shall be applicable to all locations and installations, **including manufactured homes**.

Therefore, effective immediately the Electrical Bureau will adhere to the 2002 NEC 210.63 with the following policy revision: Any receptacle not within 25 feet, for the servicing of HVAC equipment will be considered in violation of the Code.